

# Energy performance certificate (EPC)

15 Amaryllis Drive  
Apley  
Telford  
TF1 6AZ

Energy rating

**B**

Valid until: **27 September 2033**

Certificate number: 9837-4531-4000-0008-6226

Property type

Tŷ pêr

Total floor area

71 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's current energy rating is B. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		96 A
81-91	B	84 B	
69-80	C		
55-68	D		
39-54	E		
21-38	F		
1-20	G		

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Walls	Trawsyriannedd thermol cyfartalog 0.20 W/m <sup>2</sup> K	Very good
Roof	Trawsyriannedd thermol cyfartalog 0.11 W/m <sup>2</sup> K	Very good
Floor	Trawsyriannedd thermol cyfartalog 0.12 W/m <sup>2</sup> K	Very good
Windows	Gwydrau dwbl llawn	Good
Main heating	Bwyler a rheiddiaduron, nwy prif gyflenwad	Good
Main heating control	Rheolaeth amser a rheolaeth parthau tymheredd	Very good
Hot water	O'r brif system	Good
Lighting	Goleuadau ynni-isel ym mhob un o'r manau gosod	Very good
Air tightness	Athreiddedd aer 4.8 m <sup>3</sup> /h.m <sup>2</sup> (wedi'i brofi)	Good
Secondary heating	Dim	N/A

### Primary energy use

The primary energy use for this property per year is 91 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## How this affects your energy bills

An average household would need to spend **£696 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £75 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 2,443 kWh per year for heating
  - 1,450 kWh per year for hot water
-

## Impact on the environment

This property's current environmental impact rating is B. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

### Carbon emissions

An average household produces 6 tonnes of CO2

---

This property produces 1.1 tonnes of CO2

This property's potential production 0.1 tonnes of CO2

---

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

---

## Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Solar water heating	£4,000 - £6,000	£75
2. Solar photovoltaic panels	£3,500 - £5,500	£655

### Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

### More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](http://www.gov.uk/improve-energy-efficiency).

---

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Samuel Snell
Telephone	03333 321 518
Email	<a href="mailto:sam.snell@buildaviator.co.uk">sam.snell@buildaviator.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/027437
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	28 September 2023
Date of certificate	28 September 2023
Type of assessment	<a href="#">SAP</a>

---